

Current Appliance 2094658



CLIENT DETAILS	
Company Name:	SimplyPats
Address:	Waterside House Falmouth Road Penryn Cornwall TR10 8BD

DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	RSR Systems
Address:	Waterside House Falmouth Road Address 3 Penryn Cornwall TR10 8BD
Telephone:	01326 378268
Fax:	01326 378268
Email:	support@simplypats.co.uk
Signature:	<i>Your Signature</i>
Order Number:	
File Name:	Example File.PAT

For Appliance: 2094658					
Appliance Id:	2094658	Test Date:	23/02/2011	Time:	13:00
Appliance:	WATER CHILL AQUATOR	Retest Period:	12	Retest Date:	23/02/2012
Appliance SN:	AQUA-22541	Class:	I	Fuse Rating:	5 Amps
Site:	DONCASTER	PAT Serial No:	6410-922/090909/9230		
Location:	KITCHEN	User:	CM		

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)							Optional / Additional Tests				Other Tests	
	Visual Polarity	Voltage	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Touch Leakage (mA)	Sub Leakage (mA)	Flash (mA)	Clamp (mA)	Microwave (mW/cm2)	RCD Trip Time (mS)
Result	—	—	0.10	50.00	0.51	<0.10					0.00	0.00
Limit	—	—	0.75	2.00	—	2.00						
Output	—	—			—					—	—	
Status	P S	—	P	P	P	P	S	S	S	S		

Fail Reason:

Overall Status: **PASS**

OTHER INFORMATION RELATING TO APPLIANCE OR WORK CARRIED OUT	
Test Price:	Portable Appliance
Extra Notes	
Repair Description	Qty